



Environmental and Laboratory Services

90 1/2 West Blackwell St., Dover, New Jersey 07801

(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: May 8, 2017

Client: North Caldwell Public Schools
Address: 35 Hamilton Dr East
North Caldwell, NJ 07006

Project: Gould School

Sample description: Drinking Water / 1st Draw / DWS5267-1
Sample location: Hallway by Science Bubbler
Sampled by: M. Wontor
Sample date: 04/25/17
Time: 06:59
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	04/28/17	20:12	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5267-2
Sample location: Teacher's Room Sink
Sampled by: M. Wontor
Sample date: 04/25/17
Time: 07:01
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	04/28/17	20:18	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5267-3
Sample location: Field Blank
Sampled by: M. Wontor
Sample date: 04/25/17
Time: 06:59
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	04/28/17	20:24	1	2.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Laurette Young (For SV)
Susan VanVeen, Lab Manager
NJ Laboratory Certification ID # 14013

May 8, 2017
Date